

Certification Report

Report No.: CR-1:170606

Issue Date: Mar/31/2025

CUSTOMER INFORMATION

Name: Brentwood Industries
Address: Tomas Alva Edison Park, Boulevard Corredor Tijuana-Rosarito 20
 Int MT-3C, Zona Cerril General
City: Tijuana
State: B.C.
ZIP: 22330

EQUIPMENT INFORMATION

ID Number: CR-1
Manufacturer: N/A
Model: N/A
Description: Clean Room
Serial Number: N/A

This is to certify, that the test results recorded in the attached test report are correct, accurate and were conducted in accordance with the requirements of the applicable standards mentioned in this document. Therefore, only covers the tests in the test report. With the issuance of this certificate, Test Solutions de México, S.A. de C.V. accepts full responsibility for the accuracy of the test results and certification. This certification expires on the due date indicated. All the equipment used is traceable through a National Metrology Institute (NMI), as well as the National Institute of Standards and Technology (NIST) and/or the Centro Nacional de Metrología (CENAM).

This Certification Report complies with the requirements of ISO/IEC 17025:2017, and shall not be reproduced, except in full, without the written permission of the Laboratory issuing this report.

TEST INFORMATION

Area Status: "Operational" **Class:** ISO-7 / ISO-8
Test Interval: Yearly **Type:** Non-Unidirectional
Test Date: Mar/26/2025 **Performed by:** Enrique Ramirez
Due Date: Mar/26/2026 **Procedure Used:** ISO 14644-1 & 3
Temperature: 20.8°C
Humidity: 43.6% RH
Tech Comments: Attached Data Sheet(s).

This Clean Room complies with the standards; ISO 14644-1:2015, ISO 14644-3:2019, IEST-RP-CC006.3 & IEST-RP-CC034.4.

REFERENCE STANDARD

Asset #	Description	Cal. Date	Due Date	Traceability #
237	Met One 3413 Particle Counter	May/13/2024	May/13/2025	1711525014
247	TSI Alnor EBT731 Balometer	Dec/11/2024	Dec/11/2025	EBT731814021
268	Met One 3413 Particle Counter	Nov/14/2024	Nov/14/2025	1909525015
343	Rotronic HP32 / HC2A-S Humidity & Temperature Meter	Sep/02/2024	Sep/02/2025	5230734 / 20682778

Q.A. Representative: Lilia Esmeralda Adame Valdez

